Creative Construction Conference 2019, CCC 2019, 29 June - 2 July 2019, Budapest, Hungary

Probabilistic risk appraisal and mitigation of critical infrastructures for seismic extreme events

Alon Urlainis, Igal M. Shohet

Structural Engineering Department, Ben-Gurion University of the Negev, Beer-Sheva, Israel

Abstract

The importance and the interdependencies of critical infrastructures such as power and water supply, communications, and healthcare is increasing continuously and constantly. Most of the vital services for the private and the public sectors depend on the continuous performance of critical infrastructures. However, the last decades' extreme events reveal a significant gap between the preparedness of critical infrastructures and the actual risk that those infrastructures are exposed to in case of seismic event. In this research a methodology is developed to appraise and mitigate the risk that critical infrastructures are exposed to in case of seismic events. The proposed method is designated also to act as decision support tool for the selection of the most advantageous strategy to reduce the risk expectancy for extreme seismic events. A Probabilistic Seismic Hazard Analysis (PSHA) approach is used in order to reflect a variety of possible seismic scenarios and overcome the uncertainties regarding to the timing, the location, and the magnitude of an earthquake. The seismic vulnerability of different components is evaluated by adjusted fragility curves and Fault-Tree-Analysis. The seismic risk function, that expresses the expected risk of the system for a given ground motion intensity, is derived according to the occurrence probabilities of the earthquake, the seismic vulnerability of different components, and the expected consequences. This paper introduces the developed methodology and demonstrates the key steps through two case studies of oil pumping plant and oil tank farm. The pumping plant case study demonstrates the development of the risk function and examines the contribution of a possible mitigation strategy on the overall risk expectancy. The oil tank farm case demonstrates a derivation of an exclusive fragility function for critical infrastructures facility. This methodology provides a novel analytical and decision-support tool that integrates between the components adjusted fragility curves in the risk assessment and the consequent mitigation step; the optimal mitigation strategy is derived from the fragility parameters reflection on the total risk function.

© 2019 The Authors. Published by Budapest University of Technology and Economics & Diamond Congress Ltd.

Peer-review under responsibility of the scientific committee of the Creative Construction Conference 2019.

Keywords: Critical infrastructure; Risk appraisal; Risk Mitigation; Fragility curves; Earthquakes;

1. Introduction

Critical Infrastructures (CI) play a crucial role in the normal performance of the economy and society. Over the last decades the amount and the variety of critical infrastructures grew rapidly, and the interdependency between them increased constantly; consequently, more and more essential services depend on the continuous performance of one, two or even more critical infrastructures such as power, water supply, communications, etc.

As was observed in previous studies, there is a significant gap between the stability and the preparedness level of CIs for seismic events and the actual damage that those facilities are exposed to in a case of a seismic event [1-2]. The consequences of the latest seismic events emphasize the importance to mitigate the seismic risk by increasing the

*Corresponding author: Igal M. Shohet email: igals@bgu.ac.il

preparedness of CIs and ensuring reliable and robust performance on a continuous basis, particularly during and after the occurrence of extreme events. Implemented mitigation strategy is derived according to the financial constraints and depends on decision makers' policy. Therefore, at first, in order to clarify the actual risk that CIs are exposed to in case of seismic event the risk should be quantified. Subsequently, in case the risk is not acceptable, different mitigation strategies must be examined in order to select the most optimal strategy, in accordance with the economic feasibility.

The major objective of this research is to develop a probabilistic methodology that examines the preparedness of critical infrastructures through an appraisal of the risk that CIs are exposed in case of seismic events and provide a decision support tool for risk mitigation. Prior methodologies for risk appraisal [3-6] presented procedures that offer tools such as fragility curves, fault-tree-analysis (FTA), and logic tree in order to appraise the risk of different components. Those methodologies presented tools to appraise the risk for existing generic infrastructures based on empiric data. However, those studies didn't examine different mitigation strategies and their effectiveness on the risk reduction and didn't derive the optimal strategy. Moreover, those methodologies are mainly used in order to appraise the risk as a result of a particular earthquake event.

The present methodology is intended to expand prior risk appraisal tools such as fragility curves and fault-tree-analysis and implement them as a decision support tool for policy making. This methodology intends to quantify the seismic risk by a probabilistic seismic analysis of a variety of possible seismic scenarios and examine different mitigation strategies in order to obtain the optimal mitigation strategy under the given financial constraints.

2. Methodology

2.1. Seismic Hazards Identification

The seismic risk for each CI's component is identified according to the location of the facility according probabilistic seismic hazard analysis (PSHA) as presented by [7]. The PSHA approach is intended to consider all possible scenarios according to geological data about the possible earthquake sources, and the probability of magnitude and intensity occurrence that is associated with those events. The PSHA approach requires ground-motion attenuation models that estimate the expected ground-motions at a given site as a result of different intensity and location earthquakes, several studies offer attenuation models for different location and regions [8, 9]. This step yields an Annual Rate of Exceedance curve (PE_A) as a function of a given ground motion intensity measure (IM); when in most cases, for above-ground structures the IM is expressed in terms of peak ground acceleration (PGA) [10-12].

2.2. System's Seismic Vulnerability

In this step, the expected damage state as a result of a seismic event is formulated in terms of fragility curve. The fragility curve expresses the probability of reaching or exceeding certain damage states for a given level of IM [13-16]. This function is fully defined by determination of two parameters: median capacity of the component to resist the damage state (θ) and standard deviation of the capacity (β).

$$P[DS \geq ds | IM = x] = \Phi\left(\frac{\ln(x/\theta_{ds})}{\beta_{ds}}\right); ds \in \{1, 2, \dots, N_D\} \quad (1)$$

Eq. 1 expresses a formulation of a fragility function. P stands for a conditional probability of being at or exceeding a particular Damage State (DS) for a given seismic intensity, and x is defined by the earthquake Intensity Measure (IM).

Where,

DS Uncertain damage state of a particular component. $\{0, 1, \dots, N_n\}$

ds A particular value of DS

N_D	Number of possible damage states
IM	Uncertain excitation, the ground motion intensity measure (i.e. PGA, PGD, or PGV)
x	A particular value of IM
Φ	Standard cumulative normal distribution function.
θ_{ds}	The median capacity of the component to resist damage state ds measured in terms of IM
β_{ds}	Logarithmic standard deviation of the uncertain capacity of the component to resist damage state ds

In this step, the fragility parameters can be yield on the existing values that are available for generic components based on prior studies [4, 6, 12, 17]. However, in the case of a unique system or component, it is preferable to develop exclusive values for the system in accordance with the fragility of the sub-component.

2.3. Damage Assessment due to seismic Extreme Events for different components

This step associates a damage ratio (DR_i) with each damage state; DR_i expresses the percentage of the total replacement value of a component corresponding to damage state i . Subsequently, since the damage ratio is associated directly with the damage state, the expectant damage ratio of a component (DR_c) can be calculated as follows:

$$DR_c = \sum_{ds} DR_i \cdot P(ds_i | IM) \quad (2)$$

Where

DR_i Damage rate of the damage state i

$P(ds_i | IM)$ Conditional probability of being in a certain damage state i for a given IM

Furthermore, the expected repair cost (RC_c) of the component for a given IM can be calculated regarding to the replacement value (RV_c); when the RV_c expresses the total replacement cost of the component. Thus, one can calculate the expected direct damage of the component for any given IM as follows:

$$RC_c(IM) = RV_c \cdot \sum_{ds} DR_i \cdot P(ds_i | IM) = DR_c \cdot RV_c \quad (3)$$

2.4. Risk Appraisal according to expected damage

The product of this step is a seismic risk curve that presents the expected annual risk for any given value of IM. Since risk represents the potential impact and loss and it is defined as the product of the occurrence probability and the expected consequences, this curve is developed by multiplying the annual rate of exceedance curve with the direct damage curve by matching between the PGA values in both curves and links the expected consequence and its probability to occur. This matching produces a curve that correlated between the expected damage in terms of annual expectancy of risk and the PGA.

$$R_A(IM) = RC_c(IM) \cdot PE_A(IM) \quad (4)$$

Where

$R_A(IM)$ Annual risk for a given IM

$RC_c(IM)$	Replacement cost of the component for a given IM
$PE_A(IM)$	Annual rate of exceedance of a given IM

2.5. Risk Mitigation

In this step, different mitigation strategies are examined in order to predict the effectiveness of each mitigation strategy on the preparedness of the CIs by quantifying the reduction of risk followed by implementation of each strategy. Each examined mitigation strategy has different effects on the robustness and the resilience of the system which is reflected in different parameters of the fragility curve; those changes will affect the risk level. Subsequently, the optimal strategy is selected according to the level of risk reduction given the economic constraints.

3. methodology implementation: Case study 1

This chapter demonstrates a conceptual implementation of the methodology through a case study of an oil pumping plant (PP). Pumping plants serve to maintain the flow of oil across pipeline systems. They are located at certain intervals along the pipeline network to ensure the transport over long distances and around the storage facilities when the pressure must be increased due to friction losses. In addition, Pumping is also required to transport oil uphill wherever this is required due to topographic conditions.

The annual rate of exceedance curve depends on the specific location of the facility. Therefore, in this case, the pumping plant is assumed to be located in Beer-Sheva, Israel. A simplified annual rate of exceedance curve (Figure 1) was derived based on the values that were published by the Geophysical Institute of Israel report [18]. In this report, the attenuation is based on the model of [19] which has a good correlation to the Middle-East seismic patterns. This attenuation model considers a sufficient range of magnitudes (4-8.5g.) and allows considering the effects of weak seismic areas. Moreover, this attenuation considers the main parameters of site effect such as: Magnitude (M), distance from rupture (R), fault mechanism, and soil stiffness.

Figure 1 - Annual rate of exceedance curve for west Beer-Sheva region

According to [6] the failure of a pumping plant is most likely to occur as a result of damage to one of its main sub-components: the building, one or more pumps, electrical equipment, and electric power and backup systems.

In this case, the fragility parameters are based on the values proposed by [4] for unanchored pumping plant (Figure 2), the damage ratio of the tank is based on the estimate damage ratio that proposed by [4], and the replacement cost for a pumping plant is estimated at 1M US\$.

Table 1. Damage states definitions and parameters of an oil pumping plant and the damage ratio values as proposed by [4]

Damage state (DS_i)		Damage Definition	θ	β	DR_i
DS_1	Slight/minor	Light damage to building	0.12	0.60	0.08
DS_2	Moderate	Considerable damage to mechanical and electrical equipment, or considerable damage to building	0.24	0.60	0.40
DS_3	Extensive	Building being extensively damaged, or pumps badly damaged.	0.77	0.65	0.80
DS_4	Complete	Building being in complete damage state	1.50	0.80	1.00

Following the above parameters (Table 1), the risk function is derived by an integration of the annual rate of exceedance curve with the fragility curve, the damage ratio (DR_c), and the replacement value (RV_c). The risk curve analysis shows that low-moderate ground accelerations, where the exceeded PGA is less than 0.8g, have a major contribution to the total annual risk of the pumping station (Figure 3).

Figure 2 - Fragility curve for pumping plant

Figure 3 - Risk curve for pumping plant

One of the possible methods to reduce the potential damage of the PP in case of seismic event is anchoring the subcomponents of the station. This strategy is increasing the resistance of the subcomponents to overcome moderate level ground accelerations and subsequently increases the robustness of the pumping plant for seismic events. Implementation of this strategy modifies the fragility curve parameters for ds_1 and ds_2 , which gives a relatively high probability to exceed this damage states in case of moderate ground accelerations for the unanchored plant while anchoring the subcomponents reduces the probabilities to exceed ds_1 , ds_2 in case of moderate ground accelerations (Figure 4). This mitigation strategy reduces the total risk of the pumping plant. The reduction profoundly affects the damage that expected as a result of moderate ground motion. An analysis of the derived risk curves for unanchored and anchored plants shows that anchoring the components can reduce the risk by about 27% (Figure 5).

Figure 4 - Comparison of ds_1 and ds_2 for anchored and unanchored pumping plant

Figure 5 - Comparison of the risk curve for anchored and unanchored pumping plant

4. Seismic vulnerability function: Case study 2

This chapter demonstrates the derivation of a fragility function for exclusive critical infrastructures facility through a case study of an oil tank farm. In case of an exclusive facility or component of a system, it is desired to derive and use the best fit fragility curve. The main purpose of this step is to produce a unique fragility based on an aggregation of the fragilities of the sub-components (Figure 6). In this example, it is considered that the oil tank farm is composed of five main sub-components: building, storage tanks, power grid, backup generator, and mechanical equipment.

4.1. Building

The control center of the farm is in a low-rise building. The building serves for the control and the supervision of the ongoing operation of the farm. In this case, the building is a one-story RC structure. The fragility parameters are based on [6].

4.2. Tanks

Oil storage tanks are used for storage of different petroleum products for a long or a short-term time; the oil farm consists of several storage tanks. The modern oil storage tanks are varying from 12-76m in diameter with heights to diameter ratio (H/D) less than one. The most common design type of tanks is cylindrical ground-supported tank due to their efficient resistance to hydrostatic pressure and can be easily constructed. In addition, most of the oil storage facilities are composed of welded steel with floating roof. Several fragility parameter sets are offered by the literature based on empirical data. The HAZUS procedure provides data for steel tanks categorizing the tank only whether it is anchored or unanchored. In addition, [6, 10] suggest to consider parameters such as H/D ratio and tank fill level. In this case, the fragility parameters are based on the values proposed for tanks with H/D ratio less than 0.7, which are the most compatible for oil farm tanks. Moreover, in case of tank farm, the fragility of the farm will be yielded in accordance with the damage states definition, and as a binomial distribution of k damaged tank of n total tanks in the farm.

4.3. Diesel generator

The diesel generator is used as emergency power-supply in case of external power grid failure. The generator is mostly varying by capacity, vibration isolation, and anchoring. In this case, the backup generator is a diesel generator with a

Capacity of 350 to 750 kVA with unanchored equipment and without vibration isolation. The fragility parameters are based on [4, 20].

4.4. Power grid

The operation of the site is based on the ongoing supply of electric power. In this case, the electric power supply is based on two sources: In routine, the electric power supply to the facility is based on the local electricity distribution networks. in case, of a malfunction or damage to the external electrical path, a generator is placed in the facility to provide a solution until the electricity supply is restored. For this case study, the fragility parameters of the power grid are based on the HAZUS methodology [4].

4.5. Mechanical equipment

For this case study, the fragility parameters for the mechanical equipment are based on HAZUS methodology [4].

Figure 6 – Fragility curves of the oil tank farm system's sub-components – Case study 2

4.6. Development of the system fragility curve

Based on the fragility parameters of the sub-components and the system's damage state definitions, one can develop a unique fragility curve for each particular system, in the present case, an oil tank farm. The fragility curve is composed of several curves that express the sequential damage states of the system. At the last step of the fragility development, the evaluation of the fragility parameters of each damage state (θ_{ds} and β_{ds}) are derived. Figure 7 below presents the fragility curves of the oil tank farm based on those parameters.

Figure 7 - Fragility curve of an oil tank farm – Case study 2

4.7. Comparison with the literature

A comparison of the results with fragility parameters that are proposed by [4] are presented in Table 2. The differences between the parameters are most likely due to the differences in the definition of the events that attributed to each damage state. It is required to perform further analysis to examine the sensitivity of the scenarios that are defined to each damage state and to associate the scenarios with the various fragility curves.

Table 2 - Comparison of this paper results with fragility parameters that are proposed by (NIBS 2004)

Damage State	This research		NIBS 2004 [4]	
	θ	β	θ	β
Slight/minor	0.10	0.27	0.12	0.55
Moderate	0.15	0.52	0.23	0.55
Extensive	0.30	0.64	0.41	0.55
Complete	0.40	0.74	0.68	0.55

5. Sensitivity Analysis

The proposed methodology is coping with several uncertain parameters that are essential for seismic risk appraisal. The uncertainty of the seismic event is expressed in annual rate of exceedance, and the uncertainty of the damage because of the event is expressed by the fragility curve. The fragility curve process aggregates the parameters of several fragility functions which are mainly based on prior studies. For some sub-components, several sources offer different fragility parameters for the sub-component. In these cases, relying on one of the sources will, in some way, affect the risk curve. Therefore, it is highly important to examine the influence range and the sensitivity of the uncertain parameters. This sensitivity analysis examines the marginal cost of the sub-component median.

The following Tables present examination of the sensitivity of the median to the damage state of each sub-component ($\Delta\theta_{ds\ sub-component}$) and the following change on the medians of the tank farm damage states ($\Delta\theta_{ds\ oil\ farm}$) by value, the value in brackets expresses the percentage change. The first row represents the original values followed by three levels of changes in the median parameter: 50% reduction, 50% increase, and 100% increase.

Table 3 – Summary of the sensitivity analysis by sub-component. The value in brackets expresses the percentage change.

Sub-component			Oil Tank Farm			
			0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
	DS_i	DS_i^*	DS_1	DS_2	DS_3	DS_4
Building	$DS_1 = 0.1$	0.05 (-50%)	0.049 (-40%)	0.128 (0%)	0.296 (30%)	0.4 (0%)
		0.15 (50%)	0.1 (22%)	0.128 (0%)	0.296 (30%)	0.4 (0%)
		0.2 (100%)	0.107 (30%)	0.128 (0%)	0.296 (30%)	0.4 (0%)
	$DS_2 = 0.15$	0.075 (-50%)	0.061 (-26%)	0.073 (-43%)	0.228 (0%)	0.4 (0%)
		0.225 (50%)	0.088 (7%)	0.162 (27%)	0.228 (0%)	0.4 (0%)
		0.3 (100%)	0.089 (9%)	0.183 (43%)	0.228 (0%)	0.4 (0%)
	$DS_3 = 0.3$	0.15 (-50%)	0.074 (-10%)	0.103 (-20%)	0.138 (-39%)	0.4 (0%)
		0.45 (50%)	0.083 (1%)	0.135 (5%)	0.282 (24%)	0.4 (0%)
		0.6 (100%)	0.083 (1%)	0.137 (7%)	0.315 (38%)	0.4 (0%)
	$DS_4 = 0.4$	0.2 (-50%)	0.077 (-6%)	0.111 (-13%)	0.159 (-30%)	0.2 (-50%)
		0.6 (50%)	0.082 (0%)	0.132 (3%)	0.259 (14%)	0.596 (49%)
		0.8 (100%)	0.082 (0%)	0.133 (4%)	0.274 (20%)	0.777 (94%)
Tanks	$DS_1 = 0.67$	0.335 (-50%)	0.081 (-1%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		1.01 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		1.34 (100%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
	$DS_2 = 1.18$	0.59 (-50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		1.77 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		2.36 (100%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
	$DS_3 = 1.56$	0.78 (-50%)	0.082 (0%)	0.128 (0%)	0.227 (0%)	0.4 (0%)
		2.34 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		3.12 (100%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
	$DS_4 = 1.79$	0.9 (-50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.389 (-3%)
		2.685 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		3.58 (100%)	0.082 (0%)	0.133 (4%)	0.274 (20%)	0.777 (94%)
Generator	$DS_1 = 0.9$	0.45 (-50%)	0.082 (0%)	0.128 (0%)	0.218 (-4%)	0.4 (0%)
		1.35 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		1.8 (100%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
Power grid	$DS_1 = 0.15$	0.075 (-50%)	0.064 (-22%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		0.225 (50%)	0.083 (1%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		0.3 (100%)	0.083 (1%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
	$DS_2 = 0.6$	0.3 (-50%)	0.081 (-1%)	0.125 (-2%)	0.228 (0%)	0.4 (0%)
		0.9 (50%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
		1.2 (100%)	0.082 (0%)	0.128 (0%)	0.228 (0%)	0.4 (0%)
Equipment	$DS_1 = 0.60$	0.3 (-50%)	0.081 (-1%)	0.123 (-4%)	0.228 (0%)	0.4 (0%)
		0.9 (50%)	0.082 (0%)	0.129 (1%)	0.228 (0%)	0.4 (0%)

	1.2 (100%)	0.082 (0%)	0.129 (1%)	0.228 (0%)	0.4 (0%)
--	------------	------------	------------	------------	----------

This examination reveals that the most significant sub-component in most cases is the building; the fragility curve parameters of the entire system are most sensitive to inaccuracy in the fragility parameters of the building. However, in most cases the change in the farm medians is much smaller than the change in the sub-components median. Moreover, because of the complexity of the system, an inaccuracy of a single parameter will not significantly affect the risk of the entire system.

6. Conclusion

This paper introduces a probabilistic risk appraisal methodology intended for decision support tool for priority setting of mitigation strategies based on the seismic risk expectancy of critical infrastructures. The paper presents an implementation of the methodology through two case studies: pumping plant case and an oil tank farm case. The pumping plant case demonstrates the development of a seismic risk function. In this case, the risk expectancy curve reveals that the majority of the risk is concentrated at the low-moderate peak ground accelerations levels. A possible mitigation strategy was examined, and the subsequent reduction of risk was analyzed. It was found that the most effective mitigation strategy can reduce the overall risk expectancy by over 25%. Moreover, this paper focuses on the development of an exclusive fragility curve for a unique system, for these cases in which the generic fragility curves, available in the literature, are insufficient. The implantation of this approach is presented through an oil tank farm case study; in this illustration, the oil tank farm is composed of five main sub-components: building, storage tanks, power grid, backup generator, and mechanical equipment. Subsequently, based on the fragility parameters of the sub-components and the system damage state definition, the fragility curve of the system was yielded. A comparison of the results with fragility parameters that are proposed in the literature reveals that the differences between the parameters are most likely due to the differences in the definition of the events attributed to each damage state. Furthermore, a preliminary sensitivity analysis of the uncertain parameters (median of the damage states of the various sub-components) was performed; it was found that due to the complexity of the system, an inaccuracy of a single parameter, in most cases, will have insignificant effect on the total risk expectancy of the entire system.

References

- [1] S.M. Baldrige and J.D. Marshall, "Performance of structures in the January 2010 MW 7.0 Haiti earthquake," *Struct. Congr. - Proc. Struct. Congr.*, 14th April 2011 through 16th April 2011, pp. 1660-1671. [https://doi.org/10.1061/41171\(401\)145](https://doi.org/10.1061/41171(401)145)
- [2] A. Urlainis, I.M. Shohet, R. Levy, D. Ornai and O. Vilnay, "Damage in Critical Infrastructures Due to Natural and Man-made Extreme Events—A Critical Review," *Procedia Engineering*, vol. 85, pp. 529-535. <https://doi.org/10.1016/j.proeng.2014.10.580>
- [3] W.G. Corley, P.F. Mlakar Sr., M.A. Sozen and C.H. Thornton, "The Oklahoma city bombing: Summary and recommendations for multihazard mitigation," *J.Perform.Constr.Facil.*, vol. 12, no. 3, pp. 100-112. [http://dx.doi.org/10.1061/\(ASCE\)0887-3828\(1998\)12:3\(100\)](http://dx.doi.org/10.1061/(ASCE)0887-3828(1998)12:3(100))
- [4] NIBS, "HAZUS-MH: users's manual and technical manuals. Report prepared for the Federal Emergency Management Agency. National Institute of Building Sciences,".
- [5] ALA, "American Lifelines Alliance. Guideline for Assessing the Performance of Oil and Natural Gas Pipeline Systems in Natural Hazard and Human Threat Events,".
- [6] P. Gehl, N. Desramaut, A. Réveillère and H. Modaressi, "Fragility Functions of Gas and Oil Networks," pp. 187-220. https://doi.org/10.1007/978-94-007-7872-6_7
- [7] J.W. Baker, "An introduction to probabilistic seismic hazard analysis," *White Paper Version*, vol. 2, no. 1, pp. 79.
- [8] N.A. Abrahamson, "Abrahamson & Silva NGA ground motion relations for the geometric mean horizontal component of peak and spectral ground motion parameters," *PEER Report Draft v2, Pacific Earthquake Engineering Research Center, Berkeley, CA*, pp. 380.
- [9] N. Abrahamson and W. Silva, "Summary of the Abrahamson & Silva NGA ground-motion relations," *Earthquake Spectra*, vol. 24, no. 1, pp. 67-97. <https://doi.org/10.1193/1.2924360>
- [10] M.J. O'Rourke and P. So, "Seismic fragility curves for on-grade steel tanks," *Earthquake Spectra*, vol. 16, no. 4, pp. 801-815 <https://doi.org/10.1193/1.1586140>.
- [11] M. Razzaghi and S. Eshghi, "Development of Analytical Fragility Curves for Cylindrical Steel Oil Tanks," October 12-17.
- [12] ALA, "American Lifelines Alliance. Seismic fragility formulations for water systems," 2001.
- [13] K. Porter, R. Kennedy and R. Bachman, "Creating fragility functions for performance-based earthquake engineering," *Earthquake Spectra*, vol. 23, no. 2, pp. 471-489. <https://doi.org/10.1193/1.2720892>
- [14] K. Porter, R. Hamburger, and R. Kennedy, "Practical development and application of fragility functions,".

- [15] J.W. Baker, "Efficient analytical fragility function fitting using dynamic structural analysis," *Earthquake Spectra*, vol. 31, no. 1, pp. 579-599. <https://doi.org/10.1193/021113EQS025M>
- [16] A. Urlainis, I.M. Shohet, and R. Levy, "Probabilistic risk assessment of oil and gas infrastructures for seismic extreme events," *Procedia Engineering*, vol. 123, pp. 590-598. <https://doi.org/10.1016/j.proeng.2015.10.112>
- [17] M. O'Rourke, "Analytical fragility relation for buried segmented pipe," *Proceedings of the TCLEE 2009: Lifeline Earthquake Engineering in a Multihazard Environment*, pp. 771-780. [https://doi.org/10.1061/41050\(357\)73](https://doi.org/10.1061/41050(357)73)
- [18] A. Klar, T. Meirova, Y. Zaslavsky and A. Shapira, "Spectral acceleration maps for use in SI 413 amendment No.5,".
- [19] K.W. Campbell and Y. Bozorgnia, "NGA ground motion model for the geometric mean horizontal component of PGA, PGV, PGD and 5% damped linear elastic response spectra for periods ranging from 0.01 to 10 s," *Earthquake Spectra*, vol. 24, no. 1, pp. 139-171. <https://doi.org/10.1193/1.2857546>
- [20] FEMA, "Seismic Performance Assessment of Buildings - FEMA P-58,".